

EC DECLARATION OF CONFORMITY

VSO-32E Conventional Fire Alarm Base Sounder Audible Warning Device

This document certifies that the product/s above is/are in accordance with the Construction Products Regulation EU N° 305/2011, in accordance with the EC Directive 2014/30/EU for Electro Magnetic Compatibility (EMC) and EC Directive RoHS (2011/65/EU), including the amendment Directive 2015/863 (RoHS 3) to which this declaration relates and conform to the relevant parts of the following standards:-

BS EN 50130-4:2011 + A1:2014
BS EN 61000-6-3:2007 + A1:2011
EN 54-3:2001 + A1:2002 + A2:2006 and Annex ZA.1

Which includes the following technical standards:-

EMC Directive 2014/30/EU	BS EN 61000-4-3:2006 + A1:2008 + A2:2010 BS EN 61000-4-6:2014 BS EN 61000-4-2:2009 BS EN 61000-4-4:2012 BS EN 61000-4-5:2014 + A1:2017 BS EN 55022:2010
RoHS Directive 2011/65/EU	BS EN IEC 63000:2018

To be used in accordance with installation instructions and in conjunction with:
116-099 - Cover Plate (sales part number 507-006) and sounder tones 1 - LF Sweep, 3 - Alternative Warble, 11 - Dutch Sweep Tone, 25 - German DIN Tone and 27 - French Afnor as referred to in tone list on datasheet. Also includes Off White (-O), Alternative White (-A) and Ivory White (-I).

**Tested and Certified by BRE Global Ltd & BRE Global Assurance Ireland Ltd
(EU Notified Body number 2831)**

Name of Authorised Signatory: Neil Young

Position in Company: Business Unit Director

Signed:  _____

Date: 04/01/2021

Place of Manufacture: Cranford Controls Limited,
Unit 2 Waterbrook Estate, Waterbrook Road, Alton,
Hampshire, GU34 2UD, UK.

Authorised Representative: Apollo Gesellschaft für Meldetechnologie mbH,
Am Anger 31, 33332 Gütersloh, Germany.

EC DECLARATION OF PERFORMANCE

1. Unique Product identification code:
VSO-32E range of products

2. Type, batch or serial number or any other element allowing identification of the construction product as required pursuant to Article 11(4):
Fire Alarm Devices - Audio Alarm Device incl. 507-001, 507-020, 507-007, 507-026

3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:
Fire detection and fire alarm systems installed in and around buildings.

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to Article 11(5):
Cranford Control Limited,
Unit 2 Waterbrook Estate,
Waterbrook Road, Alton,
Hampshire, GU34 2UD.

5. Where applicable, name and contact address of the Authorized Representative whose mandate covers the tasks specified in Article 12(2):
Apollo Gesellschaft für Meldetechnologie mbH,
Am Anger 31, 33332 Gütersloh, Germany.

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V:
System 1

7. In case of the declaration of performance concerning a Construction Product covered by the harmonized standard:
Tested and Certified by BRE Global Ltd & BRE Global Assurance Ireland Ltd.
(EU Notified Body number 2831)

Performed type testing and the initial inspection of the manufacturing plant and of the factory production control with continuous surveillance assessment and approval of the factory production control under system 1 and issued the EC certificates of conformity:
2831-CPR-F0095

8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:
Not applicable.

9. Declared performance:

All requirements including all Essential Characteristics and the corresponding performances for the intended use or uses indicated in 3. have been determined as described in the hEN mentioned in the following table.

Essential characteristics	Performance	Harmonized European Standard		
			EN54-3: 2001 A1: 2002, A2: 2006	Notes
Performance under fire conditions	Pass		4.2, 4.3, 5.2, 5.3, C.3.1., C.3.2., C.5.1., C.5.2., C.5.3	
Operational reliability	Pass		4.4, 4.5, 4.6, 5.4, C4	
Durability of operational reliability, Temperature resistance	Pass		5.5, 5.6, 5.7, 5.8, 5.9	5.6 applies to Type A outdoor sounders
Durability of operational reliability, Humidity resistance	Pass		5.8, 5.9, 5.10	5.10 applies to Type B outdoor sounders
Durability of operational reliability, Corrosion resistance	Pass		5.11	
Durability of operational reliability, Shock and Vibration resistance	Pass		5.12 to 5.15	
Durability of operational reliability, Electrical stability	Pass		5.16	
Durability of operational reliability, Resistance to ingress	Pass		5.17	

10. The performance of the product identified in 1. and 2. is in conformity with the declared performance in 9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in 4.

Signed for and on behalf of Cranford Controls Limited by:

Date: 04/01/2021

Signed:



Neil Young

